

***Annual Drinking Water Quality Report for 2025***  
***Town of Greenville, 11159 Route 32***  
***Greenville N.Y. 12083***  
***(Public Water Supply ID#1900028)***

## **INTRODUCTION**

To comply with State regulations, The Town of Greenville, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Joseph Myers Operator at 518-966-5055 ext.4. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled town board meetings, the meetings are held the third Monday of each month at 7PM at the town hall meeting room located at 11159 Rt 32.

## **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 1,100 people through 351 service connections. Our water source is provided by three wells, two are located on Wickes Lane and the third is located off of Country Estates Road. The water is chlorinated for disinfection purposes and treated with a corrosion control inhibitor prior to distribution. Additionally we filter the water through greensand filters to control taste and odor problems.

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to the drinking water sources were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells.

The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. While nitrates (and other inorganic contaminants) were detected in our water, it should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence of contaminants does not necessarily indicate that the water poses a health risk. The nitrate levels in our sources are not considered high in

comparison with other sources in this area. See section “Are there contaminants in our drinking water?” for a list of the contaminants that have been detected.

As mentioned before, our water is derived from three drilled wells. The source water assessment has rated these wells as having a medium-high susceptibility to microbials, nitrates, industrial solvents, and other industrial contaminants. These ratings are due primarily to the close proximity of permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government), low intensity residential activities, septic systems, and an unregulated facility using hazardous substances within the assessment area. In addition, the wells draw from an unconfined aquifer of unknown hydraulic conductivity. While the source water assessment rates our wells as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State’s drinking water standards for microbial contamination. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted below.

### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA’s Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health – Oneonta District Office at 607-432-3911.

<b>Table of Detected Contaminants</b>							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCL G	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
<u>Copper</u>	No	9/26/2025	0.3 <sup>1</sup> Range: 0.057 – 0.316	mg/l	1.3	AL = 1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
<u>Lead</u>	No	9/26/2025	3 <sup>2</sup> Range: ND – 3	ug/l	0	AL = 15	Corrosion of household plumbing systems and service lines connecting building to water mains, erosion of natural deposits
Barium	No	3/20/2025	WTP A <sup>3</sup> = 0.18 WTP B <sup>3</sup> = 0.183	mg/l	2	MCL = 2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	No	3/20/2025	WTP A <sup>2</sup> = 0.45 WTP B <sup>2</sup> = 0.42	mg/l	N/A	MCL = 2.2	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nickel	No	3/20/2025	WTP A <sup>3</sup> = 0.0009 WTP B <sup>3</sup> = 0.0009	mg/l	N/A	N/A	Naturally Occurring
Combined radium – 226 and 228	No	10/13/2022	WTP B <sup>3</sup> = 0.82	pCi/l	0	MCL = 5	Erosion of natural deposits.

Bromomethane (Methyl Bromide)	No	10/9/2025	WTP A <sup>3</sup> = 0.6	ug/l	N/A	MCL = 5	Used to kill a variety of pests; used to make other chemicals or as a solvent to get oil out of nuts, seeds, and wool.
Chloromethane (Methyl Chloride)	No	10/9/2025	WTP A <sup>3</sup> = 1.8 WTP B <sup>3</sup> = 0.78	ug/l	N/A	MCL = 5	Used in organic chemistry; used as an extractant for greases, oils, and resins; as a solvent in the rubber industry; as a refrigerant, blowing agent and propellant in polystyrene foam production; as an anesthetic; as an intermediate in drug manufacturing; as a food additive, a fumigant, and a fire extinguisher.
Total Trihalomethanes (TTHMs – chloroform, bromodichloromethane, dibromochloromethane, and bromoform)	No	9/11/2025	13.9	ug/l	N/A	MCL = 80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains organic matter.
Haloacetic Acids (mono-, di-, and trichloroacetic acid, and mono- and di-bromoacetic acid)	No	9/11/2025	2.2	ug/l	N/A	MCL = 60	By-product of drinking water disinfection needed to kill harmful organisms.

1 – The level presented represents the 90th percentile of the 12 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 12 samples were collected at your water system and the 90th percentile copper value was the second highest value (0.3 mg/l). The action level for copper was not exceeded at any of the sites tested.

2 – The level presented represents the 90th percentile of the 12 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead values detected at your water system. In this case, 12 samples were collected at your water system and the 90th percentile lead value was the second highest value (3 ug/l). The action level for lead was not exceeded at any of the sites tested.

3 – WTP A treats water from Wickes Lane wells, WTP B treats water from Country Estates Road well.

**Definitions:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Level 1 Assessment:** A Level 1 assessment is an evaluation of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is an evaluation of the water system to identify potential

problems and determine, if possible, why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Non-Detects (ND)**: Laboratory analysis indicates that the constituent is not present.

**Nephelometric Turbidity Unit (NTU)**: A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Milligrams per liter (mg/L)**: Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Micrograms per liter (ug/L)**: Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**Nanograms per liter (ng/l)**: Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

**Picograms per liter (pg/l)**: Corresponds to one part per of liquid to one quadrillion parts of liquid (parts per quadrillion – ppq).

**Picocuries per liter (pCi/L)**: A measure of the radioactivity in water.

**Millirems per year (mrem/yr)**: A measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)**: A measure of the presence of asbestos fibers that are longer than 10 micrometers.

## **WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements. We are required to present the following information on lead in drinking water:

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Greenville Water District is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact the town of Greenville Water Dept. at (518)966-5055 X 2 Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

## **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

We are required to monitor your drinking water for specific contaminants on a regular basis. We are also required to submit reports, operational information, and water sample results to the Department of Health in a timely manner. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2025, we did not provide a copy of a complete and accurate 2024 Annual Water Quality Report to the Department of Health by the required submittal deadline. We also

did not certify to the Department of Health that the 2024 Annual Water Quality Report was distributed to customers as required by the regulations.

## **INFORMATION ON LEAD SERVICE LINE INVENTORY**

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by request at the Town Hall located at 11159 Rt. 32 Greenville NY 12083

## **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

## **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.